

Invisible **Structures' Memo**



Date: 7-28-08 [revised 12-30-10]
To: Kevin Cobaugh
From: Kate Wright
Re: Geogrid use in a Rainstore3 chamber

Kevin,

This memo is regarding the use of geogrid in a Rainstore3 chamber. Our specification calls for the Tensar TriX 160 or equivalent for all three layers in a Rainstore3 chamber. The following geogrids are considered equivalents and are acceptable for use with our system:

Mirafi BasXGrid 12
Secugrid 30/30-Q1
Tenax MS 330
Terragrid B120
Synteen SF12
Enkagrid Max 30
Huesker Fornit 30
TerraFix BX3000

Please contact me directly if you have any questions – 303-395-1809.

Thanks,
Kate Wright
Staff Engineer

Invisible Structures, Inc. • www.invisiblestructures.com
1600 Jackson St., Suite 310 • Golden, Colorado 80401
USA/Canada Toll-Free Ph: 800-233-1510 Fax; 800-233-1522
Local and Overseas Ph: (USA)303-233-8383 Fax: (USA)303-233-8282